

Hazardous Substance & Waste Management Research, Inc.

2976 Wellington Circle West Tallahassee, Florida 32309 Phone: (850) 681-6894 Fax: (850) 906-9777 www.hswmr.com

FROM: Dr. Christopher M. Teaf

President & Director of Toxicology

TO: Laymon Gray

Associate Director

Environmental Health & Safety

Florida State University

DATE: 02 March 2023

SUBJECT: Lewis-Greene House - Radon Evaluation

The Lewis-Greene House (Lewis-Greene) at Florida State University (FSU) has been evaluated for radon content due to indoor air quality questions that have been raised regarding other buildings on the FSU campus. From February 6 to 8, 2023, radon measurements were collected at three (3) locations at Lewis-Greene. The 48-hour charcoal-liquid scintillation vial measurements were collected by a state-certified radon contractor, in accordance with standard protocols of the United States Environmental Protection Agency (USEPA) and the Florida Department of Health (FDOH). None of the radon values at any location were greater than the 4 picoCurie/liter (pCi/L) USEPA Action Level (range 2.3 to 2.5 pCi/L). Results for the February 2023 sampling event are summarized in the attached table.

Detectable radon levels are ubiquitous throughout the state, with most areas of Florida exhibiting low radon. Outdoor levels typically are in the 0.4 to 0.5 pCi/L range, and indoor levels regularly range from 1 to 2 pCi/L. Radon comes from decay of natural radium, and elevated indoor radon is related to local geology. Radon often is present in clays, phosphate rock, and igneous rocks, like granite, and can originate from bedrock far below land surface. Because it is a naturally occurring substance, exposure is common and unavoidable.

The data summarized herein reflect a condition that is consistent with many buildings in Florida and throughout the United States, and the radon conditions at the Lewis-Greene House do not represent a health concern. Further investigation regarding radon is not recommended at this time.

HSWMR Established 1985

RADON MEASUREMENTS - Lewis-Greene House, Florida State University

| Location | Sampling Dates | Number of Samples | Min pCi/L | Max pCi/L | Notes |
|-------------|------------------------|----------------------|---------------------|---------------------|----------------------|
| First Floor | 06 to 08 February 2023 | 3 | 2.3 | 2.5 | No results > 4 pCi/L |

pCi/L = picocuries per liter