

Hazardous Substance & Waste Management Research, Inc.

2976 Wellington Circle West Tallahassee, Florida 32309 Phone: (850) 681-6894 Fax: (850) 906-9777 www.hswmr.com

FROM: Dr. Christopher M. Teaf

President & Director of Toxicology

TO: Laymon Gray

Associate Director

Environmental Health & Safety

Florida State University

DATE: 02 August 2023

SUBJECT: FSU Biology Unit 1 - Radon Evaluation

The Biology Unit 1 building (Bio Unit 1) at Florida State University (FSU) has been evaluated for radon content due to indoor air quality questions that have been raised regarding other buildings on the FSU campus. From July 10 to 12, 2023, radon measurements were collected at thirteen (13) locations at Bio Unit 1. The 48-hour charcoal canister measurements were collected by a state-certified radon contractor, in accordance with standard protocols of the United States Environmental Protection Agency (USEPA) and the Florida Department of Health (FDOH). None of the radon values were greater than the 4 picoCurie/liter (pCi/L) USEPA Action Level (range of < 0.4 to 1.0 pCi/L). Results for the July 2023 sampling event are summarized in the attached table.

Detectable radon levels are ubiquitous throughout the state, with most areas of Florida exhibiting low radon. Outdoor levels typically are in the 0.4 to 0.5 pCi/L range, and indoor levels regularly range from 1 to 2 pCi/L. Radon comes from decay of natural radium, and elevated indoor radon is related to local geology. Radon often is present in clays, phosphate rock, and igneous rocks, like granite, and can originate from bedrock far below land surface. Because it is a naturally occurring substance, exposure is common and unavoidable.

The data summarized herein reflect a condition that is consistent with many buildings in Florida and throughout the United States, and the radon conditions at the Biology Unit 1 building do not represent a health concern. Further investigation regarding radon is not recommended at this time.

HSWMR Established 1985

RADON MEASUREMENTS - Biology Unit 1, Florida State University

Location	Sampling Dates	Number of Samples	Min pCi/L	Max pCi/L	Notes
First Floor	10 Jul to 12 Jul 2023	13	< 0.4	1.0	No results > 4 pCi/L

pCi/L = picocuries per liter