

---

# HSWMR

---

## Hazardous Substance & Waste Management Research, Inc.

2976 Wellington Circle West  
Tallahassee, Florida 32309  
Phone: (850) 681-6894  
Fax: (850) 906-9777  
www.hswmr.com

**FROM:** Dr. Christopher M. Teaf  
President & Director of Toxicology

**TO:** Laymon Gray  
Associate Director  
Environmental Health & Safety  
Florida State University

**DATE:** 11 October 2023

**SUBJECT:** FSU Warehouse 3 Labor and Construction - Radon Evaluation

The Warehouse 3 Labor and Construction building (Labor and Construction) at Florida State University (FSU) has been evaluated for radon content due to indoor air quality questions that have been raised regarding other buildings on the FSU campus. From September 12 to 14, 2023, radon measurements were collected at four (4) locations at Labor and Construction. The 48-hour charcoal canister measurements were collected by a state-certified radon contractor, in accordance with standard protocols of the United States Environmental Protection Agency (USEPA) and the Florida Department of Health (FDOH). All of the radon values were less than the 4 picoCurie/liter (pCi/L) USEPA Action Level (all results below detectable levels at <0.4 pCi/L). Results for the September 2023 sampling event are summarized in the attached table.

Detectable radon levels are ubiquitous throughout the state, with most areas of Florida exhibiting low radon. Outdoor levels typically are in the 0.4 to 0.5 pCi/L range, and indoor levels regularly range from 1 to 2 pCi/L. Radon comes from decay of natural radium, and elevated indoor radon is related to local geology. Radon often is present in clays, phosphate rock, and igneous rocks, like granite, and can originate from bedrock far below land surface. Because it is a naturally occurring substance, exposure is common and unavoidable.

The data summarized herein reflect a condition that is consistent with many buildings in Florida and throughout the United States, and the radon conditions at the Warehouse 3 Labor and Construction building do not represent a health concern. Further investigation regarding radon is not recommended at this time.

### RADON MEASUREMENTS - Warehouse 3 Labor and Construction, Florida State University

Location	Sampling Dates	Number of Samples	Min pCi/L	Max pCi/L	Notes
First Floor	12 to 14 Sep 2023	4	<0.4	<0.4	No results > 4 pCi/L

pCi/L = picocuries per liter