
HSWMR

Hazardous Substance & Waste Management Research, Inc.

2976 Wellington Circle West
Tallahassee, Florida 32309
Phone: (850) 681-6894
Fax: (850) 906-9777
www.hswmr.com

FROM: Dr. Christopher M. Teaf
President & Director of Toxicology

TO: Laymon Gray
Associate Director
Environmental Health & Safety
Florida State University

DATE: 17 November 2023

SUBJECT: FSU Panama City Campus - Radon Evaluation

The Panama City Campus buildings of Florida State University (FSU) have been evaluated for radon content due to indoor air quality questions that have been raised regarding other buildings on the FSU main campus in Tallahassee. From October 16 to 18, 2023, radon measurements were collected at 122 locations from nine buildings at the Panama City Campus. The 48-hour charcoal canister measurements were collected by a state-certified radon contractor, in accordance with standard protocols of the United States Environmental Protection Agency (USEPA) and the Florida Department of Health (FDOH). All of the radon values in all of the buildings were less than the 4 picoCurie/liter (pCi/L) USEPA Action Level (ranging from below detectable levels at <0.4 pCi/L to 1.32 pCi/L). Results for the October 2023 sampling event are summarized in the attached table.

Detectable radon levels are ubiquitous throughout the state, with most areas of Florida exhibiting low radon. Outdoor levels typically are in the 0.4 to 0.5 pCi/L range, and indoor levels regularly range from 1 to 2 pCi/L. Radon comes from decay of natural radium, and elevated indoor radon is related to local geology. Radon often is present in clays, phosphate rock, and igneous rocks, like granite, and can originate from bedrock far below land surface. Because it is a naturally occurring substance, exposure is common and unavoidable.

The data summarized herein reflect a condition that is consistent with many buildings in Florida and throughout the United States, and the radon conditions at the Panama City Campus buildings do not represent a health concern. Further investigation regarding radon is not recommended at this time.

RADON MEASUREMENTS - Panama City Campus Buildings, Florida State University

Location	Sampling Dates	Number of Samples	Min <i>pCi/L</i>	Max <i>pCi/L</i>	Notes
Ground Contact Floors	16 to 18 Oct 2023	122 samples in 9 buildings	<0.4	1.3	No results > 4 pCi/L Action Level

pCi/L = picocuries per liter

Buildings Evaluated

- Seminole Landing Apartments
- Holley Academic Center
- Faculty Building B
- Bay Building C
- Auditorium Building
- Barron Building
- Bland Conference Center
- Admin Services Center
- Technology Building